

Patterson, Connie

From: Kolczynski, John
Sent: Tuesday, June 4, 2019 2:50 PM
To: Patterson, Connie
Subject: RE: 2019-368 BRADLEY POND PUD REVIEW

Connie,

I only have one comment for the PUD:

- All roads are to be 24' wide from edge of pavement to edge of pavement.

John F. Kolczynski E.I.
Traffic Studies Associate Engineer
Traffic Engineering Division
1007 Superior Street
Jacksonville, Florida 32254
(904) 255-7547

From: Patterson, Connie
Sent: Tuesday, June 04, 2019 11:11 AM
To: Salem, Soliman; Parola, Helena; Kolczynski, John; Sands, Mike; McCoy, Tanja; Warnock, Blaine; McDaniel, Jody; Joseph, Daryl; Namey, Joe; Hubsch, Charles; Price, Mollie L.; West, Susan R. - Consulting Engineer; Gallup, William R.; Lamb, John T.; Wilson, Kurtis
Subject: RE: 2019-368 BRADLEY POND PUD REVIEW

Sending again. The file was too large.

From: Patterson, Connie
Sent: Tuesday, June 4, 2019 11:06 AM
To: Salem, Soliman <Soliman@coj.net>; Parola, Helena <HParola@coj.net>; Kolczynski, John <JohnFK@coj.net>; Sands, Mike <MSands@coj.net>; McCoy, Tanja <TMcCoy@coj.net>; Warnock, Blaine <Warnock@coj.net>; McDaniel, Jody <JodyM@coj.net>; Joseph, Daryl <DJoseph@coj.net>; Namey, Joe <Namey@coj.net>; Hubsch, Charles <CHUBSCH@coj.net>; Price, Mollie L. <pricml@jea.com>; 'West, Susan R. - Consulting Engineer' <westsr@jea.com>; 'Gallup, William R.' <GallupW@duvalschools.org>; Lamb, John T. <John.Lamb@jaxsheriff.org>; Wilson, Kurtis <KRWilson@coj.net>
Subject: 2019-368 BRADLEY POND PUD REVIEW

Good Afternoon,

The Current Planning Division of the Planning and Development Department would appreciate any comments or recommendations that your agency/department may have on the proposed development. Please review the attached and e-mail your comments or recommendations to this office no later than: **Friday, June 7, 2019.**

Connie Patterson

City Planner II
City of Jacksonville | Planning & Development Department
214 North Hogan Street, Suite 300
Jacksonville, FL 32202
(904)255-7822

